When Fire Protection and Cooling Collide in Data Center Facilities

THE CENTRAL DESIGN QUESTION

How do we preserve fire-resistance and smoke control without compromising the thermal operating environment that keeps critical equipment online?




Figure 1. Data center airflow + FRPS integration: contained cold aisle, raised-floor supply-air plenum, hot-air return, and representative fire-rated penetration interfaces. Conceptual illustration; project-specific assemblies, listings, product documentation and AHJ requirements govern.

Abstract

Data centers present an unusual building-design problem: the same construction intended to contain fire and smoke is repeatedly penetrated by the systems required to power, cool, monitor, connect and maintain information-technology equipment. As rack densities rise and cooling architectures become more sophisticated, the interfaces among fire-resistance-rated construction, airflow, pressure relationships, cable infrastructure, equipment supports and monitoring systems become increasingly consequential.

A small penetration can create disproportionate risk if it interrupts a rated assembly, forms an unintended smoke path, alters a pressure relationship or interferes with the thermal-management strategy. This paper examines those interfaces and presents an FRPS strategy based on early coordination, engineered fire-rated products, vent-flow pathway management and lifecycle documentation.

DESIGN PRINCIPLE

Protect the required fire- and smoke-resisting construction without compromising the engineered operating environment.

The Building Is Part of the Cooling System

In a modern mission-critical facility, the enclosure does more than separate rooms. Ceilings, wall assemblies, floors, plenums, equipment galleries, containment structures and service pathways influence how heat moves through the facility. The building therefore participates directly in the environmental-control strategy serving the IT equipment.

ASHRAE TC 9.9 identifies equipment placement, airflow patterns, thermal envelopes and equipment heat-load and airflow requirements as fundamental data-center design considerations. Current ASHRAE guidance also treats hot/cold aisle layout, containment and reduction of bypass and recirculation as foundational air-management practices for efficient, reliable operation.

This means a construction decision that changes airflow resistance or pressure relationships can become an operational decision. Conversely, an airflow opening that crosses a required rated boundary becomes a life-safety design issue. The two disciplines meet at the penetration.

Why Passive Fire Protection Becomes Difficult at Scale

Data centers concentrate extraordinary numbers of penetrations: power distribution, conduit, cable tray, fiber, copper, busway, controls, cameras, environmental sensors, detection systems, recessed devices, mechanical services and containment supports. Many are repetitive; many change after turnover.

The code framework is assembly-specific. The International Building Code addresses penetrations and membrane penetrations in

fire-resistance-rated construction, while UL evaluates complete fire-resistance, penetration-firestop and joint systems using defined test methods. A generic note to "firestop all penetrations" does not establish whether a particular field condition matches a tested or listed system.

The design risk is cumulative. Hundreds of individually minor openings can become a major coordination and inspection problem when their protection strategy is inconsistent or undocumented.

The High-Consequence Failure is Usually an Interface Failure

Mission-critical failures often occur between disciplines rather than within them. The architect defines the rated assembly; the mechanical engineer defines airflow; electrical and technology teams define power and communications pathways; containment contractors define support interfaces; fire-protection teams define detection and suppression. Each scope may be internally correct while the assembled condition remains unresolved.

A poorly coordinated penetration can create several problems simultaneously: diminished compartmentation, an unintended smoke route, an airflow bypass, a thermal hot spot, a noncompliant field modification, or a condition that cannot be supported by available listing documentation.

Because data-center operation depends on tightly managed environmental conditions, the consequence of a small interface error can be disproportionate to the size of the opening itself.

Vent Flow Pathway Management: Not Every Opening Should Be Sealed

Vent flow pathway management begins by distinguishing intended airflow from unintended leakage. Intended pathways may serve supply air, return air, pressure relief, environmental monitoring or other engineered mechanical functions. Unintended pathways may result from oversized penetrations, incomplete construction, abandoned openings or changes made after commissioning.

The goal is neither to seal every opening nor to leave every airflow opening unprotected. The design team must identify which pathways are operationally necessary, which boundaries require continuity, and which tested, listed or engineered protective method is appropriate at the interface.

This is especially important where a passive-fire-protection measure could alter pressure, airflow volume, equipment inlet conditions or return-air performance.

VENT FLOW PATHWAY RULE

The objective is to protect what must be protected, preserve what must remain open, and eliminate unintended bypass pathways.

Hot/Cold Aisle Containment Creates New Rated-Assembly Interfaces

Containment improves thermal predictability by reducing mixing between equipment supply air and hot exhaust. It also introduces new architectural and MEP interfaces. Framing may terminate at ceilings; supports may penetrate horizontal construction; cable drops, lighting, sprinklers, sensors and detection systems may occupy the same zone.

A containment support passing through a rated membrane is not merely a hardware detail. A cable drop through that same assembly is not merely a technology detail. Where the construction is relied upon for fire resistance, these become multidisciplinary life-safety conditions requiring documented design resolution.

Smoke Can Use the Same Paths as Air

Airflow systems are designed to move air efficiently. During a fire event, pressure relationships and mechanical operation can also influence smoke movement. NFPA 75 addresses fire protection of information technology equipment, while NFPA 76 addresses fire protection and service continuity in telecommunications facilities. Both reinforce the importance of protecting sensitive equipment and continuity of service from the effects of fire and smoke.

An undocumented opening linking plenums, equipment spaces or adjacent compartments can therefore be both an energy/thermal problem during normal operation and a smoke-migration concern during an incident.

Cable Infrastructure Turns Firestop Into a Lifecycle Problem

Cable pathways are rarely static. Fiber is added, copper is removed, capacity grows and equipment refreshes change routing. A penetration that matches a listed condition at turnover can be altered substantially after repeated moves, adds and changes.

Reenterability, accessibility, allowable penetrants, fill limitations, identification and restoration procedures should therefore be part of the initial design. Mission-critical fire protection is not only about first-day compliance; it is also about maintaining a controllable condition over the life of the facility.

Field Improvisation is a Documentation Risk

Complex conditions encourage field-created solutions: sheet-metal boxes, gypsum pockets, oversized sleeves, improvised collars or combinations of products not originally detailed. Unique conditions can require a legitimate engineering judgment, but a plausible-looking field fix is not automatically equivalent to a tested system.

UL guidance emphasizes the use of tested and listed systems for penetrations and joints, with engineering judgments used when an appropriate tested system is unavailable. Standardizing recurring conditions before installation reduces the frequency with which the project must rely on one-off field decisions.

FRPS: Product Engineering Plus Design Coordination

FRPS approaches the problem as a system-integration challenge. The objective is to combine engineered fire-rated products with application review, vent-flow pathway coordination, construction-detail development and lifecycle documentation so recurring penetration conditions are identified before they become field conflicts.

Potential FRPS applications may include compatible recessed devices, service and cable pathways, horizontal-assembly openings, vertical wall penetrations and other recurring conditions. Selection must begin with the actual rated construction and the specific device or penetrant — not with a generic assumption that one firestop material applies everywhere.

FRPS CONSULTING CAN SUPPORT

Design Review • Penetration Classification • Vent-Flow Pathway Assessment • A/E Coordination • Construction Details • Specification Support • Submittal Planning • Installation Coordination • Lifecycle Documentation

What an Engineered FRPS Strategy Can Deliver

The value proposition extends beyond the individual product. A coordinated FRPS program can create repeatable penetration categories, more consistent details, earlier coordination between architecture and MEP, improved inspection readiness and a clearer path for future maintenance.

For owners with multiple facilities, standardization can also support campus-level design criteria, preferred detail libraries, penetration schedules and consistent turnover documentation.

Moving Passive Fire Protection Upstream

The conventional sequence is reactive: design the building, route the systems, create the openings, discover conflicts, issue RFIs, develop fixes and then document the installed condition.

A more resilient sequence is proactive: identify rated assemblies, map anticipated penetrations, classify airflow-sensitive boundaries, establish recurring penetration types, select tested or engineered solutions, integrate details into drawings and BIM, install consistently, inspect and preserve the records for operations.

Moving passive fire protection upstream is less visible than a new piece of equipment, but it can materially reduce rework, inspection uncertainty and lifecycle risk.

Features and Benefits by Stakeholder

ARCHITECT — Clearer rated-boundary details; fewer undefined membrane conditions; stronger coordination between life-safety plans and installed devices.

MEP ENGINEER — Ability to protect rated boundaries while preserving necessary airflow, pressure relationships, equipment access and service routing.

GC / TRADES — Repeatable details, fewer field inventions, simplified QA/QC, more predictable procurement and reduced corrective work.

COMMISSIONING / AHJ — Better traceability from assembly to penetration type to approved protection method; cleaner turnover documentation.

OWNER / OPERATOR — Maintainability, reentry planning, campus standardization and a documented pathway for future modifications.

Questions Design Teams Should Ask Before Construction

- If this opening is sealed differently in the field, could it change an intended airflow or pressure relationship?
- Does the selected protection method match the actual wall, floor, ceiling or membrane assembly?
- Will the condition remain maintainable after future cable additions or equipment changes?
- Can the project team produce the tested/listed system or approved engineering basis during inspection?
- Are containment supports, sensors, sampling tubes and low-voltage devices included in the penetration strategy — not just major ducts and conduits?
- Does the BIM model or penetration schedule distinguish intentional vent-flow pathways from leakage openings that must be closed?

RISK LENS

In mission-critical construction, a small penetration can carry a large operational consequence.

CONCLUSION

Engineer the Interface

Data centers are moving toward higher power densities, more complex cooling architectures and tighter requirements for availability. As that evolution continues, passive fire protection cannot remain an isolated closeout activity. The interface among fire-resistance-rated construction, airflow, equipment operating temperature, cable infrastructure and penetrations must be deliberately engineered.

FRPS provides a framework for addressing that interface through engineered fire-rated products and consulting services. The objective is larger than sealing a penetration: it is to create repeatable conditions in which fire resistance, smoke control, thermal performance, constructability, inspection readiness, serviceability and operational continuity are designed to coexist.

References & Technical Basis

ASHRAE Technical Committee 9.9. Thermal Guidelines for Data Processing Environments, Fifth Edition, and current mission-critical/data-center technical resources.

ASHRAE. AI Data Center Energy Performance Framework — Energy and Thermal Efficiency; recommended practices or hot/cold aisle layout, containment and reduction of bypass/recirculation.

International Code Council. 2024 International Building Code, Chapter 7 — Fire and Smoke Protection Features, including Section 714, Penetrations.

NFPA. NFPA 75, Standard for the Fire Protection of Information Technology Equipment, 2024 edition.

NFPA. NFPA 76, Standard for the Fire Protection of Telecommunications Facilities, 2024 edition.

UL Solutions. UL 263, Standard for Fire Tests of Building Construction and Materials; UL 1479, Standard for Fire Tests of Penetration Firestops; UL 2079, Standard for Tests for Fire Resistance of Building Joint Systems.

UL Solutions. Firestop and Joint Application Guide and UL Firestop Penetration Numbering guidance.

Technical / Editorial Note

This article discusses general design principles and potential FRPS applications. It is not a substitute for project-specific engineering or code analysis. Product ratings, listings, assembly configurations, penetrant types, dimensions, vent-flow characteristics and installation requirements must be verified against current product documentation, adopted codes, approved construction documents, applicable tested/listed systems and requirements of the Authority Having Jurisdiction.

About Fire Rated Product Specialties

Fire Rated Product Specialties Corp. provides engineered passive fire-protection solutions intended to help preserve fire-resistance-rated assemblies where recessed fixtures, valves, fans, lighting products, mechanical systems, electrical devices and other building-service components interrupt rated construction. FRPS supports architects, engineers, contractors, inspectors, authorities having jurisdiction, owners and property managers with application-specific products, specifications, CAD details, installation resources and building-code notices.